



March 19, 2021

Ms. Miriam Andrus, Director
Grace A. Dow Memorial Library
1710 W. St. Andrews Road
Midland, MI 48640

Re: Grace A. Dow Library
MEP Assessment and Replacement

Dear Ms. Andrus,

Please include the following as Addendum #2:

Questions and Answers

Q1. (Clarification for Q5 on addendum #1) Who is the existing building fire alarm through?

A1. Summit Fire Protection has worked on the fire protection system and Veterans Fire Alarm currently monitors the fire alarm system.

Q2. The Grace A. Dow library project on the prints page M2.1 states on the schedule notes for the water heater to furnish ASME T&P valves with the water heaters. Water Heaters come from the factory with the T&P for the specific heater already provided.

A2. Provide factory supplied T&P valve.

Q3. The model numbers listed for the water heaters are not ASME heaters; the ASME model numbers would read CGN199100A and the Alt # SWA200N. The numbers listed on the schedule are CGN199100 and SWR200N, these are regular standard heaters. Being there is a significant cost difference from the standard heaters and the ASME heater, can you clarify what heater is requested for this application as the note contradicts the listed model numbers?

A3. Provide the standard models listed in the schedule

Q4. Where is the existing cond. Unit #1 located that is referenced in keyed note 3 on E1.1?

A4. See item E1 below.

March 16, 2021

Page - 2 -

Changes

Item E1: Refer to sheet E1.1 (Sheet not reissued) Keyed note #3 shall be deleted.
Keyed note #2 shall apply to the new fire protection air compressor.

Sincerely,

MacMillan Associates, Inc.

Michael Vogtmann